

RTRT.E48898 Receptacles for Plugs and Attachment Plugs

[Page Bottom](#)

Receptacles for Plugs and Attachment Plugs

[See General Information for Receptacles for Plugs and Attachment Plugs](#)

ECHO ELECTRIC CO LTD

E48898

621 NAGAI

YATSUSHIRO-CHO

FUEFUKI-SHI, YAMANASHI 406-0823 JAPAN

Receptacles for use in fixtures or appliances, 15 amp, 125 v, Cat. Nos. AC-1, -1C, -1E, -1F, -T01, -T03, -T05, -T09, -G07.

These receptacles are for use with nonconducting face plates and, under the conditions noted here for use with conducting face plates and with devices having conducting mounting surfaces. When a receptacle is used with a conducting face plate, either caps having no exposed live parts or caps with exposed live parts so wired that there will be little likelihood of stray strands contacting the conducting face plates should be used. When a receptacle is installed on a device with a conducting mounting surface, the face of the receptacle shall project a minimum of 3/32 in. and a maximum of 3/16 in. from the mounting surface.

[Last Updated](#) on 2010-09-08

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

? 2014 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: " 2014 UL LLC".